

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING NO.** 3774-0544:100 Page 1 of 1

**CATEGORY:** Electric Locks

**LISTEE:** Locknetics Security Engineering, 575 Birch St., Forestville CT 06010  
Contact: Adam O'Day (860) 314-5248 Fax (860) 585-8629\*

**DESIGN:** Models 263, 268, 271, 350+ , 350B, 351+ , 351B, 352+ and 352B series  
electromagnet locks with or without suffix -TJ, -CLH or HDB. Refer to listee's data sheet  
for detailed product description and operational considerations.

**RATING:** 12 VDC, 24 VDC, 12/24 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances  
and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number and UL label.

**APPROVAL:** Listed as auxiliary electric door locks for use with fire rated doors as a mean of supplemental  
locking of the door in addition to the door's normal latch bolt. Authority having jurisdiction  
shall be consulted prior to installation.

**NOTE:** Formerly 4138-0544:100

\*Rev. 06-15-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 15, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager